SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

## **Artistry Hardwood Floor**

14418 Best Ave., Santa Fe Springs, CA, United States

For the following product(s):

## **Engineered Hardwood:**

1/2"-3/4": Windsor Collection, Loft Collection, Heritage Collection, Norwood Collection, Sedona Collection, Santa Fe Collection, Orleans Collection, Islands Collection, Vistas Collection, Manhattan Collection, Charleston Collection, Madison Collection, Hartford Collection

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

## **FloorScore**<sup>®</sup>

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.0

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m<sup>3</sup> (in compliance with CDPH/EHLB Standard Method v1.2-2017)

## Registration # SCS-FS-04011 Valid from: August 2, 2019 to April 30, 2020

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, http://www.scsglobalservices.com/certified-green-products-guide.





ISO/IEC 17065 Product Certification Body #0821

Stanley Mathuram, PE, Vice President SCS Global Services 2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA

